

TECHNICAL PRODUCT SUBMITTAL

AMICUS LAHP-752HT AIR SOURCE HEAT PUMP

EFFICIENCY DATA -Part L2		
Heating Capacity (EN14511) external air+7C 30/35 flow	kW	65.6
Total Power input (EN14511) external air+7C 30/35 flow	kW	15.2
COP (EN14511) external air+7C 30/35 flow	W/W	4.31
EFFICIENCY DATA -ErP and Energy Label		
Energy Label Rating Low temperature		A++
SCOP Low Temperature		4.01
Seasonal Efficiency Low temperature	%	157.5
Energy Label Rating High temperature		A+
SCOP High Temperature		3.2
Seasonal Efficiency High temperature	%	124.8
GENERAL		
Refrigerant type		R410A
Compressor Type		E.V.I. Scroll
Number of Compressors		2
Number of Circuits		1
Capacity steps		2
Minimum capacity step	%	50
ELECTRICAL DATA		
Power supply	V/Ph/Hz	415/3+N/50
Maximum input power	kW	34
Maximum input current standard unit	A (per phase)	56
Peak input current standard unit	A (per phase)	170
Peak input current unit with soft start option fitted	A (per phase)	114
Fuse rating (delayed)	A	100
Optional Hydraulic kit input power	kW	1.1
Optional Hydraulic kit maximum input current	A	2.45
FANS		
Fan type (standard unit)		Axial
Number of fans (standard unit)		2
Air flow rate for design	m ³ /h	16612
Sound power level ²	dB(A)	74
Sound pressure level ³	dB(A)	42
WATER		
Flow/Return connections	inch	2
Nominal flow rate	L/sec	4.18
Pressure drop across the heat exchanger	kPa	17.9
Minimum water content in the user circuit	litre	700
BREEAM DATA		
Total refrigerant charge	kg	15.2
Operational life	Years	20
Global warming potential		2088

TECHNICAL PRODUCT SUBMITTAL

AMICUS LAHP-752HT AIR SOURCE HEAT PUMP



LAHP-752HT			Heating OUT						Max Outlet	
Water Delivery Temperature			35C	40C	45C	50C	55C	60C		65C
performance data	-10	Heat Output (KW)	39.0	39.0	39.0	38.8	38.3	38.0	37.5	65°C
		Efficiency COP	2.6	2.3	2.1	1.8	1.7	1.5	1.3	
	-9	Heat Output (KW)	40.0	40.1	40.1	39.9	40.1	39.4	38.7	65°C
		Efficiency COP	2.6	2.4	2.1	1.9	1.7	1.6	1.4	
	-8	Heat Output (KW)	41.2	41.2	41.2	41.1	40.9	40.4	39.9	65°C
		Efficiency COP	2.7	2.4	2.2	2.0	1.8	1.6	1.4	
	-7	Heat Output (KW)	42.2	42.2	42.3	42.3	41.9	41.5	41.2	65°C
		Efficiency COP	2.8	2.5	2.3	2.0	1.8	1.6	1.5	
	-6	Heat Output (KW)	43.2	43.3	43.3	43.3	43.1	42.8	42.4	65°C
		Efficiency COP	2.8	2.6	2.3	2.1	1.9	1.7	1.5	
	-5	Heat Output (KW)	44.2	44.3	44.3	44.3	44.2	43.9	43.6	65°C
		Efficiency COP	2.9	2.6	2.3	2.1	1.9	1.7	1.5	
	-4	Heat Output (KW)	45.2	45.4	45.7	45.3	45.2	45.1	45.0	65°C
		Efficiency COP	3.0	2.7	2.4	2.2	1.9	1.7	1.6	
	-3	Heat Output (KW)	46.2	46.3	46.5	46.4	46.4	46.4	46.3	65°C
		Efficiency COP	3.0	2.7	2.5	2.2	2.0	1.8	1.6	
	-2	Heat Output (KW)	47.2	47.3	47.5	47.4	48.7	47.8	48.7	65°C
		Efficiency COP	3.1	2.8	2.5	2.2	2.1	1.8	1.7	
	0	Heat Output (KW)	50.8	51.2	51.5	51.9	52.0	52.6	53.6	65°C
		Efficiency COP	3.3	3.0	2.7	2.4	2.2	2.0	1.8	
5	Heat Output (KW)	61.2	61.7	62.4	63.2	63.9	64.6	65.8	65°C	
	Efficiency COP	4.0	3.6	3.3	2.9	2.7	2.4	2.2		
10	Heat Output (KW)	70.3	70.8	71.5	72.4	73.2	74.3	75.3	65°C	
	Efficiency COP	4.7	4.2	3.8	3.4	3.0	2.7	2.5		
15	Heat Output (KW)	76.7	76.9	77.4	78.2	79.1	80.2	81.2	65°C	
	Efficiency COP	5.1	4.6	4.1	3.7	3.3	3.0	2.7		
20	Heat Output (KW)	82.4	82.2	82.5	83.1	83.8	84.9	85.9	65°C	
	Efficiency COP	5.5	4.9	4.4	3.9	3.5	3.1	2.8		
25	Heat Output (KW)	87.2	86.8	86.9	87.3	88.0	88.9	89.9	65°C	
	Efficiency COP	5.9	5.2	4.7	4.1	3.7	3.3	3.0		

Optional Hydraulic kit Pump details		
Model	LAHP-752HT	
Nominal Input power	kW	
Nominal Input current	A	
Nominal water flow rate	l/h	
Total head available at the pump	kPa	
Available head for system pipework	kPa	
Power supply	V/ph/Hz	

Amicus air to water heat pumps must be installed and maintained in line with the Installation Commissioning and Maintenance Instructions which are available on the Literature & Downloads section of www.lochinvar.ltd.uk