



Number	23GR0622/00	Replaces	--
Issue date	28-03-2024	Contract number	E4722
Due date	28-03-2034	Module	B (Type testing)
Report number	P000118450	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DO3450		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **condensing central heating boilers**, model(s):

**HCB 117,
HCB 190,
HCB 235,
HCB 295**

Manufacturer

**Lochinvar Ltd
8 Lombard Way, The MXL Centre
Oxon, OX16 4TJ Banbury
United Kingdom**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2021/AC:2022 and EN 15502-2-1:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number	23GR0622/00	Replaces	--
Issue date	28-03-2024	Contract number	E4722
Due date	28-03-2034	Module	B (Type testing)
Report number	P000118450	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DO3450	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
Lochinvar Ltd

Model(s):
HCB 117, HCB 190, HCB 235, HCB 295

Appliance types:
B₂₃, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃

Appliance categories:
I_{2H}

Gas groups and supply pressures:
H: 20 mbar;

Countries:
Ireland, United Kingdom

Remarks:
--