ERP DATA TABLE

according regulations 813/2013

Information	Symbol	Unit	Value	
Trade mark	-	-	Lochinvar Ltd.	
Model Identifier	-	-	EFB155	
Condensing Boiler	-	-	Yes	
Low Temperature Boiler	-	-	No	
B1 Boiler	-	-	No	
Cogeneration Space Heater	-	-	No	
Combination Heater	-	-	No	
Rated Heat Output	P-rated	kW	140.9	
Rated Heat Output (At high temperature regime 80/60)	P4	kW	140.9	
Rated Heat Output 30% (At low temperature regime 50/30)	P1	kW	46.5	
Seasonal Space Heating Energy Efficiency	η _s	%	92.9	
Seasonal Space Heating Energy Efficiency (At high temperature regime 80/60)	η4	%	87.3	
Seasonal Space Heating Energy Efficiency (At low temperature regime 50/30)	η	%	97.8	
Auxiliary Electricity Consumption At Full Load	elmax	kW	0.278	
Auxiliary Electricity Consumption At Part Load	elmin	kW	0.031	
Auxiliary Electricity Consumption In Standby Mode	P _{SB}	kW	0.007	
Standby Heat Loss	P _{STBY}	kW	0.083	
Ignition Burner Power Consumption	P _{ign}	kW	0.0	
Sound Power Level	Lwa	dB	73	
Precautions During Assembling, Installation Or Maintenance	See Installati	See Installation, Commissioning, User & Maintenance Instructions of the product		

ErP data table_EFB155_march2019



Lombard Way, The MXL Centre, Banbury, Oxon, OX16 4TJ Tel: +44(0) 1295 269 981, Fax:+44(0) 1295 271 640, Email: <u>info@lochinvar.ltd.uk</u> www.lochinvar.ltd.uk