

# HERALD HCB61CE ERP DATA TABLE

according regulations 813/2013

Information	Symbol	Unit	Value
Trade mark	-	-	Lochinvar Ltd.
Model Identifier	-	-	HCB61CE
Condensing Boiler	-	-	Yes
Low Temperature Boiler	-	-	Yes
B1 Boiler	-	-	No
Cogeneration Space Heater	-	-	No
Combination Heater	-	-	No
Rated Heat Output	P-rated	kW	52
Rated Heat Output (At high temperature regime 80/60)	P4	kW	51.1
Rated Heat Output (At low temperature regime 50/30)	P1	kW	17.1
Seasonal Space Heating Energy Efficiency	$\eta_s$	%	94
Seasonal Space Heating Energy Efficiency (At high temperature regime 80/60)	$\eta_4$	%	88.3
Seasonal Space Heating Energy Efficiency (At low temperature regime 50/30)	$\eta_1$	%	99.8
Auxiliary Electricity Consumption At Full Load	elmax	kW	0.122
Auxiliary Electricity Consumption At Part Load	elmin	kW	0.034
Auxiliary Electricity Consumption In Standby Mode	P <sub>SB</sub>	kW	0.004
Standby Heat Loss	P <sub>STBY</sub>	kW	0.172
Ignition Burner Power Consumption	P <sub>ign</sub>	kW	0
Sound Power Level	L <sub>wa</sub>	dB	60
Precautions During Assembling, Installation Or Maintenance	See Installation, Commissioning, User & Maintenance Instructions of the product		

ErP data table\_HCB-61CE\_February 2016

