ERP DATA TABLE according regulations 813/2013

| Information | Symbol | Unit | Value |
|---|--|------|----------------|
| Trade mark | - | - | Lochinvar Ltd. |
| Model Identifier | - | - | CPM77 |
| Condensing Boiler | - | - | Yes |
| Low Temperature Boiler | - | - | No |
| B1 Boiler | - | - | No |
| Cogeneration Space Heater | - | - | No |
| Combination Heater | - | - | No |
| Rated Heat Output | P-rated | kW | 72.1 |
| Rated Heat Output (At high temperature regime 80/60) | P4 | kW | 72.1 |
| Rated Heat Output 30% (At low temperature regime 50/30) | P1 | kW | 24.1 |
| Seasonal Space Heating Energy Efficiency | η _s | % | 92.2 |
| Seasonal Space Heating Energy Efficiency (At high temperature regime 80/60) | η4 | % | 87.4 |
| Seasonal Space Heating Energy Efficiency (At low temperature regime 50/30) | η | % | 97.2 |
| Auxiliary Electricity Consumption At Full Load | elmax | kW | 0.136 |
| Auxiliary Electricity Consumption At Part Load | elmin | kW | 0.025 |
| Auxiliary Electricity Consumption In Standby Mode | P _{SB} | kW | 0.004 |
| Standby Heat Loss | P _{STBY} | kW | 0.067 |
| Ignition Burner Power Consumption | P _{ign} | kW | 0 |
| Sound Power Level | Lwa | dB | 67 |
| Precautions During Assembling, Installation Or Maintenance | See Installation, Commissioning, User & Maintenance Instructions of the product | | |

ErP data table_CPM-77_september2016



Lombard Way, The MXL Centre, Banbury, Oxon, OX16 4TJ Tel: +44(0) 1295 269 981, Fax:+44(0) 1295 271 640, Email: <u>info@lochinvar.ltd.uk</u> www.lochinvar.ltd.uk