



Certificate number: 2604721 (1)

Issued 22/04/2026
Expires 21/04/2031

Kiwa Regulation 4(KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 (issue 7) – Regulation 4(1)(a)
Model number(s) – see Appendix

Lochinvar Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Replication of this certificate is allowed in its entirety.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Lochinvar Ltd
8 Lombard Way
The MXL Centre
Banbury
Oxon
OX16 4TJ
United Kingdom



KUKreg4

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of glass lined indirectly heated storage vessels. Fitted with a temperature and pressure refile valve set at 10bar and 95°C and magnesium sacrificial anode. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) LSTHP 66 G A LSTHP 100 G A LSTHP 110 G A LSTHP 130 G A LSTHP 165 G A LSTHP 220 G A</p>
<p>SIZE: 2" inlet / outlet connection.</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground & Free Standing.</p>
<p>MARKING Approval holders logo, name and address, model number, max working pressures and other technical information.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES Expansion vessels should be installed in the vertical orientation, where expansion vessels are not installed in the vertical orientation appropriate measures should be used to ensure that there is adequate flow through of water through the expansion vessel and they are located so that the length of the connecting pipework is kept to a minimum. Sealed primary circuits and /or secondary hot water systems shall incorporate a means for accommodating the thermal expansion of water to prevent any discharge from the circuit and/or system except in an emergency situation.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p>

Extra Notes