

Certificate
26GR0322/00



Issued	22-09-2026	Replaces	--
Valid until	22-09-2036	Report number	P000411136
		PIN	0063DP3136
		Page	1 of 1

EU type-examination certificate (Module B)

Kiwa hereby declares that the **gas-fired condensing boilers, Water Heaters**, model(s):

**TTB+1200,
TTB+375,
TTB+625,
TTB+875,
TTW+1200,
TTW+375,
TTW+625,
TTW+875**

Manufacturer **Lochinvar Ltd**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 (March 9th, 2016) relating to appliances burning gaseous fuels (GAR).

Reference standard: EN 15502-2-1:2022+A1:2023 and EN 15502-1:2021+A1:2023

This certificate is only valid in combination with the annex to this certificate, where specific information and/or conditions are given.

Wim van Loon
Managing Director Nederland

This certificate has one annex.
Disclosure of the certificate is permitted.

Manufacturer:
Lochinvar Ltd

Model(s):
TTB+1200
TTB+375
TTB+625
TTB+875
TTW+1200
TTW+375
TTW+625
TTW+875

PIN:
0063DP3136

Appliance types:

B_{23P}, C_{13(X)}, C_{33(X)}, C_{43(X)}, C_{53(X)}, C_{63(X)}, C_{83(X)}, C_{93(X)}, C_{(10)3(X)}, C_{(11)3(X)}, C_{(12)3(X)}, C_{(13)3(X)}, C_{(14)3(X)}, C_{(15)3(X)},

Appliance categories:

I_{2E(R)}, I_{2E(S)}, I_{2E}, I_{2EK}, I_{2ELL}, I_{2Esi}, I_{2H}, I_{2L}, I_{3B/P}, I_{3P},
II_{2E3B/P}, II_{2E3P}, II_{2EK3B/P}, II_{2EK3P}, II_{2ELL3B/P}, II_{2ELL3P}, II_{2Esi3B/P}, II_{2Esi3P}, II_{2H3B/P}, II_{2H3P}, II_{2L3B/P}, II_{2L3P}

Gas groups and supply pressures:

B: 30 mbar; 50 mbar; 100 mbar
B/P: 30 mbar; 37 mbar; 50 mbar; 100 mbar
P: 30 mbar; 37 mbar; 50 mbar; 100 mbar
H: 20 mbar; 25 mbar; 100 mbar
E: 20 mbar; 100 mbar
K: 25 mbar; 100 mbar
L: 20 mbar; 25 mbar; 100 mbar
LL: 20 mbar; 100 mbar
E(S): 20 mbar; 25 mbar; 100 mbar
E(R): 20 mbar; 25 mbar; 100 mbar
Esi: 20 mbar; 25 mbar; 100 mbar

Countries:

Australia, Austria, Azerbaijan, Bahrain, Belgium, Bosnia Herzegovina, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Egypt, Estonia, Finland, France, Georgia, Germany, Greece, Hungary, Iceland, Ireland, Israel, Italy, Kuwait, Latvia, Liechtenstein, Lithuania, Luxembourg, Malta, New Zealand, Norway, Oman, Poland, Portugal, Qatar, Romania, Saudi Arabia, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Syria, The Netherlands, Türkiye, Ukraine, United Arab Emirates, United Kingdom

Remarks:

Appliances are suitable for the gas groups E, H and K containing up to 20 % of Hydrogen gas (H₂).